



Horizontal Tank Calibration Chart
 Tank Diameter: 108 Inches
 Tank Length: 204 Inches
 Total Tank Capacity: 8,090.1 Gallons

8,000 Gallon Tank

Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining	Inches of Void	Gallons of Sealer Remaining
1	8090.13	28	6508.50	55	4045.07	82	1581.63
2	8077.93	29	6425.40	56	3949.70	83	1499.55
3	8055.71	30	6341.33	57	3854.36	84	1418.54
4	8027.08	31	6256.34	58	3759.08	85	1338.66
5	7993.33	32	6170.47	59	3663.91	86	1259.95
6	7955.24	33	6083.77	60	3568.87	87	1182.49
7	7913.32	34	5996.28	61	3473.99	88	1106.32
8	7867.96	35	5908.04	62	3379.30	89	1031.52
9	7819.48	36	5819.10	63	3284.85	90	958.15
10	7768.12	37	5729.50	64	3190.67	91	886.28
11	7714.10	38	5548.46	65	3096.78	92	816.00
12	7657.60	39	5457.10	66	3003.22	93	747.37
13	7598.76	40	5369.27	67	2910.04	94	680.50
14	7537.74	41	5365.23	68	2817.25	95	615.47
15	7474.66	42	5272.88	69	2724.91	96	552.39
16	7409.63	43	5180.09	70	2633.03	97	491.37
17	7342.76	44	5086.91	71	2541.67	98	432.54
18	7274.14	45	4993.35	72	2450.86	99	376.03
19	7203.85	46	4899.47	73	2360.63	100	322.01
20	7131.98	47	4805.28	74	2271.03	101	270.65
21	7058.61	48	4710.83	75	2182.09	102	222.17
22	6983.84	49	4616.15	76	2093.85	103	176.82
23	6907.65	50	4521.27	77	2006.36	104	134.90
24	6830.18	51	4426.22	78	1919.66	105	96.80
25	6751.48	52	4331.05	79	1833.79	106	63.05
26	6671.59	53	4235.78	80	1748.80	107	34.42
27	6590.58	54	4140.44	81	1664.73	108	12.20

NOTE: Measurement of the void is to be done from where the actual tank starts, NOT in the manway.
 Filling tank up with sealer into the manway may result in leakage of sealer out of manway onto tank.